



CITY COUNCIL AGENDA ITEMS

To: Mayor Graham and City Council
From: Dennis Sullivan, Director of Engineering & Public Works
Walter Denton, City Administrator
Date: February 6, 2006
Subject: MOTION – WWTP Cutter Cartridge Exchange

List of committees that have reviewed: Public Works

Background: The City of O'Fallon Waste Water Treatment Plant (WWTP) has an "Auger Monster" at its intake building. The monster shreds and grinds up solids. Due to its cutting action, the cutter cartridge wears down over time. Annually, the cartridge needs to be removed and exchanged for a rebuilt one from the original manufacturer. It is time for the current cartridge to be sent back to the manufacturer for re-build.

Legal Considerations, if any: Normal concerns when contracting for material services.

Budget Impact: The \$8,800 for the exchange is built into the annual budget for the WWTP as a recurring maintenance item.

Staff recommendation: Staff recommends approving the exchange at a cost of \$8,800.