



## CITY COUNCIL AGENDA ITEMS

**To:** Mayor Graham and City Council  
**From:** Dennis Sullivan, Director of Engineering & Public Works  
Walter Denton, City Administrator  
**Date:** March 5, 2007  
**Subject:** RESOLUTION – Additional Design Services for Water Booster Pump Station

**List of Committees that have reviewed:** Public Works Committee

**Background:** Burns & McDonnell provided a proposal for additional and re-design efforts associated with staff comments on the design of the pump station. The items that require additional work are to address addition of a transmission system for use of a farm tractor PTO to drive a pump in an emergency condition, lengthening of the building to accommodate the PTO driven pump, addition of security cameras for the compound, addition of a security system, and replacement of asphalt paving with concrete paving in the compound.

**Legal Considerations, if any:** None beyond the normal ones associated with contracting for professional services.

**Budget Impact:** This is a budgeted item.

**Staff Recommendation:** Staff recommends acceptance of the proposal from Burns & McDonnell in an amount not to exceed \$36,000.