

WWTP Sludge Digester And Package Plant



Problems with the Sludge Digester and Package Plant–

- Need additional capacity to further treat sludges, reducing bacteria in sludge to be land applied.
- Metal tanks of digester and Package Plant need corrosion maintenance every 2 years.
- No backup to Sludge Digester, future improvements to Orbital Oxidation Ditch could allow conversion of Package Plant to Sludge Digester.

