

WWTP Clarifiers



Problems with the Clarifiers –

- Need additional capacity to allow removal of one clarifier at a time for annual maintenance and cleaning at minimum.
- Metal tank wall and assemblies need corrosion maintenance every 2 years.
- A third clarifier will allow for improved treatment of wastewater to meet ever tightening controls on suspended solids that are settled out in a clarifier.
- The East Clarifier's floor is bulging and rubbing on the sludge collection boom. The clarifier needs to be down for an extended period for floor replacement.

